



# 安利消防器材有限公司 Safety Fire Fighting Equipment Ltd.

消防處註冊消防裝置承辦商 • 機電工程署註冊電業承辦商

## 緊急照明出路燈箱(發光二極管) Emergency LED Exit Sign Box



ALED-B320



ALED-B415



Features	International Standards
• LED Lumen less than 5% depreciation for the first year	• IEC60598-2-22:2002 (IEC60695-2-11:2000)
• High efficiency super flux LED for higher performance	• FSD Code of Practice Clause 5.10 2005
• Discharge time more than 150 min in the emergency mode	• FSD circular letter PPA104(A) 4 <sup>th</sup> revision
• Lumen more than 230cd/m <sup>2</sup> for the first two hrs operation	• China National Accreditation Service (CNAS) IEC Standard
• Power factor > 85% & 3W power consumption	• BS 5266 Part I & BS 5499 Part III

## Specification

Model	ALED-B Series		
	ALED-B320	ALED-B415	ALED-B610
Lamp	High Flux White LED		
Line Voltage	A/C 220V, 50Hz, +/- 10%		
Battery Duration	2 Hours		
Emergency Luminance	in average 230cd/m <sup>2</sup> in DC Mode		
Battery String	Sealed Nic-Cad Rechargeable Battery 4.8V 800m Ah		
Power Consumption	3W		
Operating Temperature	0 to 40°C		
Metal Box Size (LxHxD) mm	340 x 180 x 60	415 X 180 X 60	610 X 180 X 60

Signage for Macau is available on request.

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.

香港灣仔麥加利歌街 1-19 號加達樓地下 C1 舖 website: [www.FIRE.hk](http://www.FIRE.hk) e-mail: [safety@fire.hk](mailto:safety@fire.hk)  
Shop C1, G/F, Cactus Mansion, 1-19 McGregor Street, Wan Chai, HK Tel: 2866 6895 Fax: 2866 6795