



安利消防器材有限公司 Safety Fire Fighting Equipment Ltd.

消防處註冊消防裝置承辦商 • 機電工程署註冊電業承辦商

掛牆式 LED 緊急出路燈箱 Wall Mount LED Emergency Exit Sign



| Model No. / 型號 | ALED-P320 | ALED-P405 | ALED-P570 |
|-------------------------|---|------------------|------------------|
| Box Size / 燈箱尺寸 | 365 x 85 x 45 mm | 450 x 85 x 45 mm | 610 x 85 x 45 mm |
| Plate Size / 吊牌尺寸 | 320 x 180 x 8 mm | 405 x 180 x 8 mm | 570 x 180 x 8 mm |
| Lamp | 5mm Super Bright LED Line | | |
| Discharge Duration/可亮時間 | 2 Hours | | |
| Recharge Period/充電時間 | 12 Hours | | |
| Battery/電池 | Sealed Ni-Cd 4.8V 800mAh | | |
| Power Consumption/消耗功率 | 3W | | |
| Line Voltage/電壓 | AC 220, 50 Hz, +/- 10% | | |
| Operating Temperature | 0 to 60°C | | |
| System Mode /系統模式 | 長明式 / Maintained Type | | |
| Outside features/燈外裝置 | 紅色電源指示燈、綠色充電燈及測試掣 RED Power indication light 、Green Charging Light & Test switch | | |
| Housing / 外殼 | 金屬材料，外焗塗粉狀樹脂漆油 Metal materials with Epoxy Powder Coating | | |
| Testing Report/測試證書 | 香港理工大學屋宇設備工程學系 The HK Polytechnic University - Department of Building Services Engineering | | |
| Testing Standard/測試標準 | IEC60598-2-22:2002 (IEC60695-2-11:2000) FSD Code of Practice Clause 5.10 2005 FSD Circular Letter PPA104(A) 4 th revision BS5499 Part III & BS5266 Part 1 | | |

Signage for Macau is available on request.

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.