



安利消防器材有限公司 Safety Fire Fighting Equipment Ltd.

消防處註冊消防裝置承辦商 • 機電工程署註冊電業承辦商

人仔緊急出路燈箱 Emergency Exit Sign Box



Model No. / 型號	ALED-B160	ALED-P160	ALED-PR160
Housing / 外殼	金屬材料 · 外焗塗粉狀樹脂漆油 Metal materials with Epoxy Powder Coating		
Recharge Period/充電時間	12 Hours		
Normal Output/輸出功率	3W		
Battery/電池	Ni-Cd 4.8V 800mAh		
Outside features/燈外裝置	紅色電源指示燈及測試掣 "RED" Power indication light & Test button		
Discharge Duration/可亮時間	Over 2 Hours		
System Mode /系統模式	長明式 / Maintained Type		
Testing Report/測試證書	香港大學電機電子工程學系 The University of Hong Kong Department of Electric & Electronic Engineering		
Testing Standard/測試標準	香港消防處防火組: 消防及設備守則 5.10 文件 HKFSD: FS Installations & Equipment Regulation Cap. 5.10		
Standards	BS 5266 Part 1, BS 5499 Part 3, BSEN 60598-2-22, EN61347-2-7		
Line Voltage/電壓	AC 220 - 230V 50 Hz		
Dimension/尺寸	L180 x H180 x D60mm	L260x H85xD45mm - Box L160x H160x8mm - Plate	L280xH50xD100mm - Box L160xL160x8mm - Plate

Signage for Macau is available on request.

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.

香港灣仔麥加力歌街 1-19 號加達樓地下 C1 舖 website: www.FIRE.hk e-mail: safety@fire.hk
Shop C1, G/F., Cactus Mansion, 1-19 McGregor Street, Wan Chai, HK Tel: 2866 6895 Fax: 2866 6795