



安利消防器材有限公司 Safety Fire Fighting Equipment Ltd.

消防處註冊消防裝置承辦商 • 機電工程署註冊電業承辦商

Malaysia **EVERSAFE™** Fire Extinguisher



ABC Dry Powder:

The ABC Dry Powder fire extinguisher is one of the most versatile extinguishants and is effective on Class A fires, Class B fires and Class C fires. They are also suitable for use on live electrical fires.

Carbon Dioxide:

Most effective on Class B and C fires. It is safe to use on live electrical fires. CO₂ gas is extensively used throughout the food industry for its cleanliness in application.

Water:

The most commonly used type of fire extinguishant for Class A fires involving carbonaceous material such as wood, textiles by cooling the fire and removing the heat needed for combustion.

AFFF Foam:

Effective on B class hydrocarbon fuel fires such as oil, petroleum, aviation fuels and is particularly suitable where fast knockdown is essential.

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.

TECHNICAL SPECIFICATION OF CARBON DIOXIDE, ABC DRY POWDER, FOAM & WATER FIRE EXTINGUISHERS

MODEL	EEC-2e2	EEC-5e1	EEC-2A1e2	EEC-5A1e1	EEED-1	EEED-2	EEED-2h	EEED-3	EEED-4N	EEED-6	EEED-9	EEED-12	EEEF-9s	EEEW-9s	
TYPE	STORED PRESSURE														
CAPACITY	2.0KG	5.0KG	2.0KG	5.0KG	1.0KG	2.0KG	2.0KG	3.0KG	4.0KG	6.0KG	9.0KG	12.0KG	9.0LITRE	9.0LITRE	
EXTINGUISHANT	A B C DRY POWDER														
VALVE	CONTROLLABLE CHROME PLATED BRASS VALVE WITH PRESSURE INDICATOR														
BODY DIAMETER (MM)	116	152	117	152	80	100	110	130	130	158	178	188	178	178	
OVERALL HEIGHT (MM)	520	670	520	670	332	425	410	500	580	580	630	695	635	635	
WORKING TEMPERATURE RANGE	-20°C TO +60°C														
WORKING PRESSURE	56 BAR@+20°C(169.30 BAR@+60°C)														
TEST PRESSURE	250 BAR							212 BAR							
APPROX. DISCHARGE RANGE (M)	3	3	3	3	2	2.5	2.5	4	5	5	7	7	6	6	
APPROX. DISCHARGE TIME (SEC)	14	23	14	18	9	15	13	15	20	19	22	30	68	75	
FIRE RATING	34B	55B	34B	55B	5A:34B	13A:55B	13A:70B	13A:89B	21A:113B	27A:233B	34A:233B	43A:233B	21A:183B	13A	
FIRE CLASS	B + ELECTRICAL A, B, C + ELECTRICAL														
COATING (INTERNAL)	STOVING EPOXY PRIMER														
PAINT FINISHING	SIGAL RED (RAL3000) EPOXY POLYESTER POWDER COATING														
MOUNTING	WALL BRACKET			VEHICLE BRACKET			WIRE BRACKET			VEHICLE BRACKET			WALL BRACKET		
DESIGN & MANUFACTURE TO	BS EN3:1996														



Distributed By:



安利 消防器材有限公司
Safety Fire Fighting Equipment Ltd.

Tel: 2866 6895 Fax: 2866 6795 Web: www.fire.hk

EVERSAFE EXTINGUISHER SDN. BHD. (053162-V)



CERT. No.: FM 67491
 BS EN ISO 9001:2000

In accordance with EVERSAFE™ policy of continuous improvement, specifications are subject to change without notice.