



安利消防器材有限公司 Safety Fire Fighting Equipment Ltd.

消防處註冊消防裝置承辦商 • 機電工程署註冊電業承辦商

水晶吊牌緊急出路燈箱 Emergency LED "Crystal Plate" Exit Sign Box



Model No. / 型號	LED-L4S	LED-L4R
Housing / 外殼	金屬材料，外焗塗粉狀樹脂漆油 Metal materials with Epoxy Powder Coating	
Recharge Period/充電時間	12 Hours	
Normal Output/輸出功率	3W	3W
Battery/電池	Ni-Cd 3.6V 800mAh	
Outside features/燈外裝置	紅色電源指示燈及測試掣 "RED" Power indication light & Test button	
Discharge Duration/可亮時間	Over 2 Hours	
System Mode /系統模式	長明式 / Maintained Type	
Testing Report/測試證書	香港大學電機電子工程學系 The University of Hong Kong Department of Electric & Electronic Engineering	
Testing Standard/測試標準	香港消防處防火組：消防及設備守則 5.10 文件 HKFSD: FS Installations & Equipment Regulation Cap. 5.10	
Standards	BS 5266 Part 1, BS 5499 Part 3, BSEN 60598-2-22	
Line Voltage/電壓	AC 220 - 240V 50 Hz	
Dimension/尺寸	L450 x H80 x D55 mm - Box L400 x H150 x D10 mm - Plate	L405xH66xD55mm - Recess Box L460 x H150 x D12 mm - Plate
Weight/重量	2.25 kg (Case Box) 1.0 kg (Crystal Plate)	2.75 kg (Case Box) 1.35 kg (Crystal Plate)

Signage for Macau is available on request.

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.

香港灣仔麥加力歌街 1-19 號加達樓地下 C1 舖 website: www.FIRE.hk e-mail: safety@fire.hk
Shop C1, G/F., Cactus Mansion, 1-19 McGregor Street, Wan Chai, HK Tel: 2866 6895 Fax: 2866 6795