

## 安利消防器材有限公司 Safety Fire Fighting Equipment Ltd. 消防處註冊消防裝置承辦商・機電工程署註冊電業承辦商









**L** 2866 6895 <equation-block> 2866 6795



Supalux

## Emergency **LED** Exit Sign Box

supalux	Directional Sign    Image: Control of the control o
Model	Supalux CS/G-R
Housing	Powder-coated Mild Steel
Lamp	12 Pieces High intensity SMD2835 White LEDs
LED Operating Life	≥ 50,000 hours
Rechargeable Battery	NiCd 4.8V 800mAh
Recharge Period	≤12 Hours
Rated Power	≤3.8W
Operating Temp.	0°C to 50°C
Outside Features	"Green" power indication light & "Test" switch
Charge Indicator	Green LED
Test Button	Press type
Discharge Duration	≥ 2 Hours
System Mode	Maintained Type
Input Voltage	AC 180V-242V, 50Hz
Testing Standard	HKFSD Fire Protection Command: FSD code of practice Clause 5.10 Exit Signs BS EN 60598-2-22:2008, BS5266-1: 2012, BS5499-3:1900
Weight	Case Box : 1.35kgs ; Plate : 0.80kgs Total Weight : 2.15kgs
Dimensions (L x H x D) mm	Overall visible part: L415 x H243 x W86mm
Signage Panel	EXIT 出口 or Directional
Style	Single Side or Double Sides

使膠片上蝕刻字樣及圖案更清晰易讀。LED 燈泡省電及長壽,極符合經濟效益。三年特長保養期。

All photos are for reference only. 圖片只供參考

All Technical Information is provided by Manufacturer. The Dealer is not held responsible for any inaccuracies in the data.